



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Perform Emergency Decon

Candidate # \_\_\_\_\_

**Skill No. 5-1 PERFORMANCE CRITERIA AND INSTRUCTIONS**

**INSTRUCTIONS TO THE MONITOR/EVALUATOR**

Candidate shall be provided with the following:

1. The candidate shall be given a Haz Mat scenario from which to perform.
2. The candidate shall be provided with an assistant, hose line and other equipment to fit scenario.
3. The candidate shall be given the instructions below before beginning this task.

**INSTRUCTIONS TO THE CANDIDATE**

"Given a hose line, and wearing appropriate PPE, the firefighter candidate shall perform emergency decontamination."

Minimum PPE: Full Structural PPE with SCBA

**PERFORMANCE**

Candidate must complete this skill within **15** minutes to pass.

**YES NO**

1. Confirm order with command to perform emergency decon.		
<b>C</b> 2. Ensure that all personnel involved in performing decon are wearing full, appropriate PPE.		
<b>C</b> 3. Remove or direct the victim from the contaminated area.		
<b>C</b> 4. Washes any contaminated clothing or exposed body with flooding quantities of water.		
<b>C</b> 5. Removes victims clothing or PPE rapidly, minimizing the spread of contaminants.		
<b>C</b> 6. Performs rapid head to toe rinse, wash and rinse.		
7. Transfer victim to medical personnel. Evaluates status of response objectives.		
<b>C</b> 8. Inform medical personnel about contaminant involved.		
<b>C</b> 9. Decontaminate tools and equipment.		
<b>C</b> 10. Proceed to decon line for self.		
11. Notify command of status.		

**C** Candidate performed skill in a safe manner.

Yes-  No-

Text Reference: IFSTA Haz Mat for the 1st Responder, 3rd Ed, Chap 7

**TOTALS**

--	--

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**

**FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**8**



NFPA 472:2008 Edition

Objectives: **5.1.2.2(3)(e) &(4)(a)**  
**5.4.1(4)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Operate at Haz Mat/WMD Incident

Candidate # \_\_\_\_\_

**Skill No. 5-2 PERFORMANCE CRITERIA AND INSTRUCTIONS**

**INSTRUCTIONS TO THE MONITOR/EVALUATOR**

Candidate shall be provided with the following:

1. The candidate shall be given a Haz Mat/WMD scenario from which to perform.
2. The candidate shall be provided with barricade tape, marking flags or other equipment to fit scenario.
3. The candidate shall be given the instructions below before beginning this task.

**INSTRUCTIONS TO THE CANDIDATE**

"Given a scenario, the candidate shall demonstrate scene control, evidence preservation and initiation of command."

Minimum PPE: Full Structural PPE with SCBA

**PERFORMANCE**

Candidate must complete this skill within **10** minutes to pass.

**YES NO**

<b>C</b>	1. Initiates command for incident or reports to established command supervision.		
<b>C</b>	2. Candidate identifies HOT, WARM and COLD zones.		
<b>C</b>	3. Candidate identifies or establishes barriers.		
<b>C</b>	4. Candidate identifies need for scene preservation/security, describes actions to be taken.		
	5. If under IC command, notifies command of status/actions.		

**C** Candidate performed skill in a safe manner.

Yes-  No-

Text Reference: IFSTA Haz Mat for the 1st Responder, 3rd Ed

**TOTALS**

--	--

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**

**FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**4**



NFPA 472:2008 Edition

Objectives: **5.1.1.2 (3)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Donning, Working in and Doffing PPE  
 Mission Specific/Job Duty Specific

Candidate # \_\_\_\_\_

**Skill No. 6-2A PERFORMANCE CRITERIA AND INSTRUCTIONS**

**INSTRUCTIONS TO THE MONITOR/EVALUATOR**

Candidate shall be provided with the following:

1. The candidate shall be provided an appropriate location from which to perform.
2. The candidate shall be given a duty related scenario for basis of performance.
3. The candidate shall be given the instructions below before beginning this task.

**INSTRUCTIONS TO THE CANDIDATE**

"The candidate shall dress appropriately in PPE, including respiratory protection, relevant to employment related activities, i.e. police, EMS, fire, regional haz mat response team, etc, shall work in PPE and appropriately doff PPE, when prompted by the evaluator."

Minimum PPE: Full PPE with Respiratory Protection

**PERFORMANCE**

Candidate must complete this skill within **15** minutes to pass.

YES NO

	YES	NO
<b>C</b> 1. Candidate shall demonstrate donning of PPE.		
<b>C</b> 2. Candidate shall demonstrate donning of respiratory protection.		
<b>C</b> 3. Candidate shall ensure all skin is protected from exposure.		
<b>C</b> 4. Candidate shall ensure proper fit of face piece eliminating respiratory hazards.		
<b>C</b> 5. Candidate shall demonstrate ability to work in PPE.		
<b>C</b> 6. Candidate shall demonstrate doffing of PPE.		
<b>C</b> 7. Candidate shall prevent contamination of self before and during doffing procedures.		
8. Candidate shall describe technical decon in relation to scenario.		

**C** Candidate performed skill in a safe manner.

Yes-  No-

Text Reference: IFSTA Haz Mat for the First Responder, 3rd Ed

TOTALS

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**  **FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**7**

NFPA 472:2008 Edition

Objectives: 6.2.3.1, 6.2.4.1

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Product Control  
 Absorption of Spilled Hazardous Material

Candidate # \_\_\_\_\_

**Skill No. 6-6a PERFORMANCE CRITERIA AND INSTRUCTIONS**

***INSTRUCTIONS TO THE MONITOR/EVALUATOR***

Candidate shall be provided with the following:

1. The candidate shall be given a Haz Mat scenario from which to perform.
2. The candidate shall be provided with the necessary equipment to perform task.
3. The candidate shall be given the instructions below before beginning this task.

***INSTRUCTIONS TO THE CANDIDATE***

"The candidate shall dress appropriately in structural PPE with SCBA, breathing air, and given the necessary equipment, the candidate shall perform the defensive control function of absorption."

Minimum PPE: Full Structural PPE with SCBA

**PERFORMANCE**

Candidate must complete this skill within **15** minutes to pass.

**YES NO**

<b>C</b>	1. Candidate shall demonstrate donning of PPE and SCBA for performance of task.		
	2. Confirm order with command to perform product absorption.		
<b>C</b>	3. Ensure that all personnel involved in performing a function are wearing full, appropriate PPE.		
<b>C</b>	4. Selects appropriate hand tools for task.		
<b>C</b>	5. Selects appropriate and safe location from which to perform.		
<b>C</b>	6. Selects most appropriate absorbent material for product.		
<b>C</b>	7. Deploys sorbent to effectively control product.		
<b>C</b>	8. Places contaminated material in appropriate container for disposal (verbalize).		
<b>C</b>	9. Decontaminate tools/equipment (verbalize).		
<b>C</b>	10. Advances to decon line for decontamination (verbalize).		
	11. Notify command of status.		

**C** Candidate performed skill in a safe manner.

Yes-  No-

**Text Reference:** IFSTA Haz Mat for the First Responder, 3rd Ed

**TOTALS**

--	--

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**

**FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**9**



NFPA 472:2008 Edition

Objectives: **6.2, 6.6.4.1(3)(a)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Product Control  
 Adsorption of Spilled Hazardous Material

Candidate # \_\_\_\_\_

**Skill No. 6-6b PERFORMANCE CRITERIA AND INSTRUCTIONS**

***INSTRUCTIONS TO THE MONITOR/EVALUATOR***

Candidate shall be provided with the following:

1. The candidate shall be given a Haz Mat scenario from which to perform.
2. The candidate shall be provided with adsorption type pigs or pads and other necessary equipment to perform task.
3. The candidate shall be given the instructions below before beginning this task.

***INSTRUCTIONS TO THE CANDIDATE***

"The candidate shall dress appropriately in structural PPE with SCBA, breathing air, and given the necessary equipment, the candidate shall perform the defensive control function of absorption."

Minimum PPE: Full Structural PPE with SCBA

**PERFORMANCE**

Candidate must complete this skill within **15** minutes to pass.

**YES NO**

<b>C</b>	1. Candidate shall demonstrate donning of PPE and SCBA for performance of task.		
	2. Confirm order with command to perform product adsorption.		
<b>C</b>	3. Ensure that all personnel involved in performing a function are wearing full, appropriate PPE.		
	4. Selects appropriate hand tools for task, if necessary.		
<b>C</b>	5. Selects appropriate and safe location from which to perform.		
<b>C</b>	6. Selects most appropriate adsorbent material for product.		
<b>C</b>	7. Deploys sorbent to effectively control product.		
<b>C</b>	8. Places contaminated material in appropriate container for disposal (verbalize).		
<b>C</b>	9. Decontaminate tools/equipment (verbalize).		
<b>C</b>	10. Advances to decon line for decontamination (verbalizes).		
	11. Notify command upon completion.		

**C** Candidate performed skill in a safe manner. Yes-  No-

**Text Reference:** IFSTA Haz Mat for the First Responder, 3rd Ed

**TOTALS**

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**  **FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**8**

NFPA 472:2008 Edition

Objectives: **6.2, 6.6.4.1(3)(b)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Product Control  
 Damming Spilled Hazardous Material

Candidate # \_\_\_\_\_

**Skill No. 6-6c PERFORMANCE CRITERIA AND INSTRUCTIONS**

**INSTRUCTIONS TO THE MONITOR/EVALUATOR**

Candidate shall be provided with the following:

1. The candidate shall be given a Haz Mat scenario from which to perform.
2. The candidate shall be provided with the necessary equipment to perform task.
3. The candidate shall be given the instructions below before beginning this task.

**INSTRUCTIONS TO THE CANDIDATE**

"The candidate shall dress appropriately in structural PPE with SCBA, breathing air, and given the necessary equipment, the candidate shall perform the defensive control function of damming."

Minimum PPE: Full Structural PPE with SCBA

**PERFORMANCE**

Candidate must complete this skill within **15** minutes to pass.

**YES NO**

<b>C</b>	1. Candidate shall demonstrate donning of PPE and SCBA for performance of task.		
	2. Confirm order with command to dam spilled material.		
<b>C</b>	3. Ensure that all personnel involved in performing a function are wearing full, appropriate PPE.		
<b>C</b>	4. Selects appropriate hand tools for task.		
<b>C</b>	5. Selects appropriate and safe location from which to perform.		
<b>C</b>	6. Constructs the dam in a location and manner that best controls the spill.		
<b>C</b>	7. Places contaminated material in appropriate container for disposal (verbalize).		
<b>C</b>	8. Decontaminate tools/equipment (verbalize).		
<b>C</b>	9. Advances to decon line for decontamination (verbalize).		
	10. Notify command of status.		

**C** Candidate performed skill in a safe manner.

Yes-  No-

**Text Reference:** IFSTA Haz Mat for the First Responder, 3rd Ed

**TOTALS**

--	--

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**

**FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**8**



NFPA 472:2008 Edition

Objectives: **6.2, 6.6.4.1(3)(c)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Product Control  
 Diking Spilled Hazardous Material

Candidate # \_\_\_\_\_

**Skill No. 6-6d PERFORMANCE CRITERIA AND INSTRUCTIONS**

***INSTRUCTIONS TO THE MONITOR/EVALUATOR***

Candidate shall be provided with the following:

1. The candidate shall be given a Haz Mat scenario from which to perform.
2. The candidate shall be provided with the necessary equipment to perform task.
3. The candidate shall be given the instructions below before beginning this task.

***INSTRUCTIONS TO THE CANDIDATE***

"The candidate shall dress appropriately in structural PPE with SCBA, breathing air, and given the necessary equipment, the candidate shall perform the defensive control function of diking."

Minimum PPE: Full Structural PPE with SCBA

**PERFORMANCE**

Candidate must complete this skill within **15** minutes to pass.

**YES NO**

<b>C</b>	1. Candidate shall demonstrate donning of PPE and SCBA for performance of task.		
	2. Confirm order with command to perform diking operations.		
<b>C</b>	3. Ensure that all personnel involved in performing a function are wearing full, appropriate PPE.		
<b>C</b>	4. Selects appropriate hand tools for task.		
<b>C</b>	5. Selects appropriate and safe location from which to perform.		
<b>C</b>	6. Constructs the dike in a location and manner that best controls and directs the spill.		
<b>C</b>	7. Places contaminated material in appropriate container for disposal (verbalize).		
<b>C</b>	8. Decontaminate tools/equipment (verbalize).		
<b>C</b>	9. Advances to decon line for decontamination (verbalize).		
	10. Notify command of status.		

**C** Candidate performed skill in a safe manner.

Yes-  No-

**Text Reference:** IFSTA Haz Mat for the First Responder, 3rd Ed

**TOTALS**

--	--

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**

**FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**8**



NFPA 472:2008 Edition

Objectives: **6.2, 6.6.4.1(3)(d)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Product Control  
 Diluting Spilled Hazardous Material

Candidate # \_\_\_\_\_

**Skill No. 6-6e PERFORMANCE CRITERIA AND INSTRUCTIONS**

***INSTRUCTIONS TO THE MONITOR/EVALUATOR***

Candidate shall be provided with the following:

1. The candidate shall be provided an assistant and given a Haz Mat scenario from which to perform.
2. The candidate shall be provided with a charged hand line and other necessary equipment to perform task.
3. The candidate shall be given the instructions below before beginning this task.

***INSTRUCTIONS TO THE CANDIDATE***

"The candidate shall dress appropriately in structural PPE with SCBA, breathing air, and provided with an assistant, a hand line and other appropriate equipment, shall demonstrate the appropriate action of diluting a spilled hazardous material."

Minimum PPE: Full Structural PPE with SCBA

***PERFORMANCE***

Candidate must complete this skill within **15** minutes to pass.

**YES NO**

<b>C</b>	1. Candidate shall demonstrate donning of PPE and SCBA for performance of task.		
	2. Confirm order with command to dilute a spilled hazardous material.		
<b>C</b>	3. Ensure that all personnel involved in performing a function are wearing full, appropriate PPE.		
<b>C</b>	4. Selects appropriate and safe location from which to perform.		
<b>C</b>	5. Evaluates the flow of spilled material to determine size of retention and quantity of water required to dilute the material.		
<b>C</b>	6. With assistance, candidate advances hand line to the material for dilution.		
<b>C</b>	7. Flows water appropriately to dilute the spilled material.		
<b>C</b>	8. Candidate monitors diking and damming materials to ensure integrity of retention area.		
<b>C</b>	9. Places contaminated material in appropriate container for disposal (verbalize).		
<b>C</b>	10. Decontaminate tools/equipment (verbalize).		
<b>C</b>	11. Advances to decon line for decontamination (verbalize).		
	12. Notify command of status.		

**C** Candidate performed skill in a safe manner. Yes-  No-

**Text Reference:** IFSTA Haz Mat for the First Responder, 3rd Ed

**TOTALS**

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**  **FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL. **10**

NFPA 472:2008 Edition

Objectives: **6.2, 6.6.4.1(3)(e)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
**COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION**  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Product Control  
 Diverting Spilled Hazardous Material

Candidate # \_\_\_\_\_

**Skill No. 6-6f PERFORMANCE CRITERIA AND INSTRUCTIONS**

***INSTRUCTIONS TO THE MONITOR/EVALUATOR***

Candidate shall be provided with the following:

1. The candidate shall be given a Haz Mat scenario from which to perform.
2. The candidate shall be provided with the necessary equipment to perform task.
3. The candidate shall be given the instructions below before beginning this task.

***INSTRUCTIONS TO THE CANDIDATE***

"The candidate shall dress appropriately in structural PPE with SCBA, breathing air, and given the necessary equipment, the candidate shall perform the defensive control function of diversion."

Minimum PPE: Full Structural PPE with SCBA

***PERFORMANCE***

Candidate must complete this skill within **15** minutes to pass.

**YES NO**

<b>C</b>	1. Candidate shall demonstrate donning of PPE and SCBA for performance of task.		
	2. Confirm order with command to divert spilled hazardous product.		
<b>C</b>	3. Ensure that all personnel involved in performing a function are wearing full, appropriate PPE.		
<b>C</b>	4. Selects appropriate hand tools for task.		
<b>C</b>	5. Selects appropriate and safe location from which to perform.		
<b>C</b>	6. Constructs the diversion in a location and manner that best controls and directs the spill.		
<b>C</b>	7. Places contaminated material in appropriate container for disposal (verbalize).		
<b>C</b>	8. Decontaminate tools/equipment (verbalize).		
<b>C</b>	9. Advances to decon line for decontamination (verbalize).		
	10. Notify command of status.		

**C** Candidate performed skill in a safe manner. Yes-  No-

**Text Reference:** IFSTA Haz Mat for the First Responder, 3rd Ed

**TOTALS**

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**  **FAIL**

**CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.**

NFPA 472:2008 Edition

Objectives: **6.2, 6.6.4.1(3)(f)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Product Control  
 Retaining Spilled Hazardous Material

Candidate # \_\_\_\_\_

**Skill No. 6-6g PERFORMANCE CRITERIA AND INSTRUCTIONS**

***INSTRUCTIONS TO THE MONITOR/EVALUATOR***

Candidate shall be provided with the following:

1. The candidate shall be given a Haz Mat scenario from which to perform.
2. The candidate shall be provided with the necessary equipment to perform task.
3. The candidate shall be given the instructions below before beginning this task.

***INSTRUCTIONS TO THE CANDIDATE***

"The candidate shall dress appropriately in structural PPE with SCBA, breathing air, and given the necessary equipment, the candidate shall perform the defensive control function of retention."

Minimum PPE: Full Structural PPE with SCBA

**PERFORMANCE**

Candidate must complete this skill within **15** minutes to pass.

**YES NO**

<b>C</b>	1. Candidate shall demonstrate donning of PPE and SCBA for performance of task.		
	2. Confirm order with command to perform retention of spilled hazardous product.		
<b>C</b>	3. Ensure that all personnel involved in performing a function are wearing full, appropriate PPE.		
<b>C</b>	4. Selects appropriate hand tools for task.		
<b>C</b>	5. Selects appropriate and safe location from which to perform.		
<b>C</b>	6. Evaluates the flow of spilled material to determine size of retention.		
<b>C</b>	7. Retains the material so it can no longer flow.		
<b>C</b>	8. Places contaminated material in appropriate container for disposal (verbalize).		
<b>C</b>	9. Decontaminate tools/equipment (verbalize).		
<b>C</b>	10. Advances to decon line for decontamination (verbalize).		
	11. Notify command of status.		

**C** Candidate performed skill in a safe manner.

Yes-  No-

**Text Reference:** IFSTA Haz Mat for the First Responder, 3rd Ed

**TOTALS**

--	--

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**

**FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**9**

NFPA 472:2008 Edition

Objectives: **6.2, 6.6.4.1(3)(g)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Product Control  
 Remote Valve Shutoff

Candidate # \_\_\_\_\_

**Skill No. 6-6h PERFORMANCE CRITERIA AND INSTRUCTIONS**

**INSTRUCTIONS TO THE MONITOR/EVALUATOR**

Candidate shall be provided with the following:

1. The candidate shall be given a Haz Mat scenario from which to perform.
2. The candidate shall be provided with a series of photos or props depicting remote shutoffs.
3. The candidate shall be given the instructions below before beginning this task.

**INSTRUCTIONS TO THE CANDIDATE**

"Given scenarios and illustrations of potential situations, the candidate shall identify remote valve shutoff(s) and describe proper procedures for activation of the shutoff for a depicted situation."

Minimum PPE: None

**PERFORMANCE**

Candidate must complete this skill within **10** minutes to pass.

**YES NO**

1. Confirm order with command to perform emergency remote shutoff.		
<b>C</b> 2. Candidate identifies fixed facility remote shutoff control.		
<b>C</b> 3. Candidate identifies remote shutoff on product carrier.		
<b>C</b> 4. Candidate verbalizes operation of remote shutoff.		
5. Confirms with supervisor action completed.		

**C** Candidate performed skill in a safe manner.

Yes-  No-

**Text Reference:** IFSTA Haz Mat for the First Responder, 3rd Ed

**TOTALS**

--	--

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**

**FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**4**



NFPA 472:2008 Edition

Objectives: **6.6.4.1(3)(h)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Product Control  
 Dispersion of Hazardous Vapors

Candidate # \_\_\_\_\_

**Skill No. 6-6i PERFORMANCE CRITERIA AND INSTRUCTIONS**

***INSTRUCTIONS TO THE MONITOR/EVALUATOR***

Candidate shall be provided with the following:

1. The candidate shall be provided an assistant and given a Haz Mat scenario from which to perform.
2. The candidate shall be provided with a charged hand line and other necessary equipment to perform task.
3. The candidate shall be given the instructions below before beginning this task.

***INSTRUCTIONS TO THE CANDIDATE***

"The candidate shall dress appropriately in structural PPE with SCBA, breathing air, and provided with an assistant, a hand line and other appropriate equipment, shall demonstrate the appropriate action of hazardous vapor dispersion."

Minimum PPE: Full Structural PPE with SCBA

**PERFORMANCE**

Candidate must complete this skill within **15** minutes to pass.

YES NO

<b>C</b>	1. Candidate shall demonstrate donning of PPE and SCBA for performance of task.		
	2. Confirm order with command to perform dispersion of a haz mat vapor.		
<b>C</b>	3. Ensure that all personnel involved in performing a function are wearing full, appropriate PPE.		
<b>C</b>	4. Selects appropriate and safe location from which to perform.		
<b>C</b>	5. With assistance, the candidate shall apply agent through vapor cloud to disperse vapors.		
<b>C</b>	6. Monitors leak, wind direction and stream effectiveness.		
<b>C</b>	7. Monitors exposure of personnel and environmental impact.		
<b>C</b>	8. Places contaminated material in appropriate container for disposal (verbalize).		
<b>C</b>	9. Decontaminate tools/equipment (verbalize).		
<b>C</b>	10. Advances to decon line for decontamination (verbalize).		
	11. Notify command of status.		

**C** Candidate performed skill in a safe manner.

Yes-  No-

Text Reference: IFSTA Haz Mat for the First Responder, 3rd Ed

TOTALS

--	--

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**

**FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**9**



NFPA 472:2008 Edition

Objectives: **6.2, 6.6.4.1(3)(i)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**HAZ MAT OPERATIONS COMPETENCY EVALUATION**



JPR Task: Suppression of Hazardous Vapors  
 Suppression of Hazardous Vapors

Candidate # \_\_\_\_\_

**Skill No. 6-6j PERFORMANCE CRITERIA AND INSTRUCTIONS**

***INSTRUCTIONS TO THE MONITOR/EVALUATOR***

Candidate shall be provided with the following:

1. The candidate shall be provided an assistant and given a Haz Mat scenario from which to perform.
2. The candidate shall be provided with a charged hand line, foam concentrate and proportioner equipment.
3. The equipment shall be prearranged and setup for use prior to candidate arrival.
4. The candidate shall be provided with any additional necessary equipment to perform task.
5. The candidate shall be given the instructions below before beginning this task.

***INSTRUCTIONS TO THE CANDIDATE***

"The candidate shall dress appropriately in structural PPE with SCBA, breathing air, and provided with an assistant, a hand line and other appropriate equipment, shall demonstrate the appropriate action of hazardous vapor suppression."

Minimum PPE: Full Structural PPE with SCBA

**PERFORMANCE**

Candidate must complete this skill within **15** minutes to pass.

**YES NO**

<b>C</b>	1. Candidate shall demonstrate donning of PPE and SCBA for performance of task.		
	2. Confirm order with command to perform vapor suppression.		
<b>C</b>	3. Ensure that all personnel involved in performing a function are wearing full, appropriate PPE.		
<b>C</b>	4. Selects appropriate safe and effective location from which to perform.		
<b>C</b>	5. Candidate monitors weather and spill for changing conditions.		
<b>C</b>	6. The candidate shall apply foam blanket adequate to suppress vapors, as directed by one of three (3) methods: a) Banking off an object, or b) Rolling blanket, or c) Rain down		
<b>C</b>	7. Candidate ensures integrity of foam blanket, prevents breach.		
<b>C</b>	8. Candidate verbalizes maintaining foam blanket, as necessary.		
	9. Notifies supervisor of task completion.		

**C** Candidate performed skill in a safe manner.

Yes-  No-

**Text Reference:** IFSTA Haz Mat for the First Responder, 3rd Ed

**TOTALS**

--	--

**C = Critical Step-** Failure on this step mandates failure on task !

**PASS**

**FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**7**

NFPA 472:2008 Edition

Objectives: **6.2, 6.6.4.1(3)(j)**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_